

**Radioactivity measurement for July 2020 was conducted.**

Method:

We measure our clean room air conditioning filter and report it as follows.

Result:

No detection of radioactive materials for cleaning water. Caesium was detected with External-Air Inlet Filter though, we are considering there is no influence on products as shown below.

Radioactivity Measurement (July, 2020)

Sample Category	Nuclide				Radiation Dose
	Iodine	Cesium			
Unit	I-131	Cs-134	Cs-137	Cs-136	μSv/h
	Bq/kg(L)	Bq/kg(L)	Bq/kg(L)	Bq/kg(L)	
Tap Water	ND <sup>*1</sup>	ND <sup>*1</sup>	ND <sup>*1</sup>	-	-
External-Air Inlet Filter (Logistics /Sterilization Center)	ND <sup>*2</sup> (Detection Limit : 42)	ND <sup>*2</sup> (Detection Limit : 46)	77 (Detection Limit : 44)	ND <sup>*2</sup> (Detection Limit : 35)	-

\*1) Tap water from Showa water filtering plant (Water at the water filtering plant exit): From the local government website (Period: 1st, July 2020 ~29th, July 2020)

Detection Limit: around 0.5Bq/kg

\*2) Not Detected: Below the detection limit

This time it was measurement of the External-Air Inlet Filter (Fig.1 ①) and detection of radioactive substances has stabilized at a low value for the past several years.(Table.1 "Transition of Radioactive Cesium Detection" below).

The radiation dose in the atmosphere in the environment around our factory may change temporarily due to weather such as strong winds, but does not increase up to the value in problem. Therefore we consider that there is no influence to the environment inside the Clean Room and the product manufactured inside this Clean Room.

We have confirmed through the past measurement that the External-Air Inlet Filter (Fig.1 ①) removes most of the radioactive substance, and even some substances which passed through the external filter are further removed at Internal Circulatory Filter (Fig.1 ②).  
(Investigated in July 2011).




Table.1 Transition of Radioactive Cesium Detection

Measurement period		Cs-134	Cs-137
Year	Month		
2011	May.	250.000	270.000
	Jan.	2,100	2,700
2012	Jul.	500	740
	Jan.	140	290
2013	Jul.	83	190
	Jan.	62	170
2014	Jul.	130	340
	Feb.	54	180
2015	Mar.	22	91
	Jan.	ND	36
2016	Apr.	15	79
	Sep.	ND	45
	Jan.	ND	47
2017	Mar.	11	55
	Jul.	ND	ND
	Sep.	9	74
2018	Jan.	33	360
	Mar.	ND	56
	Jul.	ND	ND
	Sep.	ND	57
2019	Jan.	ND	62
	Mar.	ND	58
	Jul.	ND	100
	Sep.	ND	27
2020	Jan.	ND	51
	Mar.	ND	ND
	Jul.	ND	77

(Bq/kg)